


DELHI JAL BOARD
(Govt. of N.C.T. Delhi)
ZONAL LABORATORY, WATER WORKS,
HAIDER PUR, DELHI-110085.

THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY

TEST REPORT

Water sample collected from primary school after R.O. near washroom in the premises of The Mann School, Holambi, Delhi - 110082 vide challan no. 252 dated 07.01.2019.

S. No.	PARAMETERS	UNITS	S1
1.	Date of collection	--	14.01.2019
2.	Date of Analysis	--	15.01.2019
3.	Colour	Hazen	Clear
4.	Odour	--	No Obj.
5.	Turbidity	N.T.U	1.02
6.	p ^H value	--	6.9
7.	Electrical Conductivity	µmhos/cm	569.0
8.	Total Dissolved Solid (mg/l)		369.85
CHEMICAL EXAMINATION			
9.	Phenolphthalein Alkalinity	(mg/l)	Nil
10.	Total Alkalinity	(mg/l)	110.0
11.	Total Hardness	(mg/l)	103.0
12.	Calcium Hardness	(mg/l)	35.0
13.	Magnesium Hardness	(mg/l)	68.0
14.	Calcium as Ca	(mg/l)	14.0
15.	Magnesium as mg	(mg/l)	16.32
16.	Ammonia (free & saline)	(mg/l)	Nil
17.	Nitrite -Nitrogen (N)	(mg/l)	Nil
18.	Nitrate (NO ₃)	(mg/l)	1.92
19.	Sulphate (SO ₄)	(mg/l)	18.44
20.	Chloride (Cl)	(mg/l)	54.0
21.	Iron (Fe)	(mg/l)	0.02
22.	Fluorides (F)	(mg/l)	0.41
23.	Cyanides (CN)	(mg/l)	Abst.
24.	Residual Chlorine	(mg/l)	Nil
BACTERIOLOGICAL EXAMINATION			
25.	Coliform per 100 ml at 37°C	MPN/100 mL	0



Remarks: On the basis of tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012, therefore it may be used for drinking purpose.

Kennel
Asstt. Chemist

15/1/19
Chemist/Bacteriologist

WSD
A.C.W.A. (HP I)

उत्तरी दिल्ली नगर निगम



NORTH DELHI MUNICIPAL CORPORATION
NARELA ZONE, NARELA, DELHI-110040

SCHOOL HEALTH CERTIFICATE

D. No. DHO/NRZ/2021/.....424.....

DATE:-20/7/21

DATE OF INSPECTION : 20/07/2021

1. NAME OF SCHOOL : **THE MANN SCHOOL**
2. ADDRESS : **HOLAMBI KHURD, DELHI-110082**
3. NO. OF SHIFTS : ONE TIMING: 08:00 AM TO 02:00 PM

ACCOMODATION PROVIDED:-

THE FLOOR AREA IN THE CLASSROOM IS **SUFFICIENT**.

THE CLASSES ARE **WELL LIGHTED**.

THE CLASSROOMS ARE **WELL VENTILATED**.

THE CLASSROOMS ARE KEPT **NEAT AND CLEAN**.

THE DRINKING WATER IS Water test Report approved by **STL Lab..**

THE TOILET ARRANGEMENT IS **SANITARY &HYGIENIC AND SUFFICIENT IN NUMBER**.


REMARKS: THIS CERTIFICATE DOES NOT INDICATES PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for a period of one year from the date of issue.

The PRINCIPAL

**THE MANN SCHOOL
HOLAMBI KHURD,
DELHI-110082**


**DY. HEALTH OFFICER
NARELA ZONE**


**Dy. Health Officer
Narela Zone**